

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2174

Dated: 22/05/26

It is certified that an inspection team headed by Sh. Rahul J.E

(Name of Officers with designation) from P.H.E.S.D. Hodal PHED

inspected the Maa Omwati Global Sr. Sec. School Hassanpur

(Name & Address of the school) on 13/05/2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. P.W.L./01474/5/2026 dated 13/05/2026

of Dist. Water Testing Laboratory Palwal (PHED Lab) certified that

the Maa Omwati Global Sr. Sec. School Hassanpur (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal: [Signature]
Name Sunder Hodal
Designation S.D.E.
Name & Address of the Office / Department :

To Maa Omwati Global Sr. Sec. School
Hassanpur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Memo No:- 870

Date:- 18/05/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : PWL/01474/5/2026 / Private	Sample Details	Date & Time
Sender : MAA OMWATI GLOBAL SR SEC SCHOOL	Collected By	MUKESH
Location : , HASSANPUR	Collection Date	13/05/2026 at 11:51
Sample Description : Drinking Water	Received at lab	13/05/2026 at 14:55
Latitude / Longitude : 77.483954 / 27.959069	Analysis Start Date	15/05/2026
	Analysis End Date	15/05/2026
	Sample Quantity	2000ml

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<1	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) 1984: RA 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) 1983: 2018
4	Color	<5	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120 B
5	Total Dissolved Solids @ 180°C ± 2°C	140	500 mg/lt.	2000 mg/lt.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	38	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2340 C
7	Calcium as Ca	5.61	75 mg/lt.	200 mg/lt.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	5.83	30 mg/lt.	100 mg/lt.	APHA 24th Edition -3500 -Mg B
9	Total Alkalinity	24	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2320 B
10	Chloride as Cl	32.98	250 mg/lt.	1000 mg/lt.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	10	200 mg/lt.	400 mg/lt.	APHA 24th Edition-4500 SO4-E
12	Fluoride as F	0.15	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500-F-D
13	Iron as Fe	<0.10	1.0 mg/lt.	1.0 mg/lt.	APHA 24th Edition-3500-Fe B
14	Nitrate as No3	3.4	45 mg/lt.	45 mg/lt.	APHA 24th Edition-4500-NO3- D
15	pH @ 25°C	6.90	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition -4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED PALWAL Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

VANDANA DESWAL ,CHEMIST
DISTRICT WATER TESTING LABORATORY,PALWAL
email:-chemist.palwal@phedharyana.gov.in

Health & Hygiene Certificate

Ref. No. CS/Pwl/2025/SHH/40

Dated. 12/8/25

In Pursuance of The Application Maa Ombati Global Sr. Sec School, Hassanpur, Palwal (Haryana) In The O/o Civil Surgeon, Palwal. The School Premises Were Inspected by Team of Health Department PHC Hassanpur on dated 01-08-2025. The School was found to Have Satisfactory Hygiene Conditions As Per The Standard Checklist of The District. This Certificate is valid up to 31-03-2026.

Date of Renewal:- 01-04-2026

Dy. Civil Surgeon (School Health)
Palwal

Dy. Civil Surgeon
PALWAL

